

Final Report

Minnesota Department of Health
Public Health Laboratory
Environmental Laboratory Section
601 Robert St. N., P.O. Box 64899
St. Paul, MN 55164-0899
651-201-5300

PWSID: St. Croix Preparatory
System Name: 4120-07
City: None

Program Code: HK

Type:

Date Received: 02/19/26 10:14
Rep. Temp. (°C): 14.1

Collector Name: Facility Staff
Collector ID: None

MDH Sample Number: 26B1348-01

Location ID: 112
Sampling Point: 460986

Collect Date: 02/16/26
Collect Time: 12:30
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6B0951	02/26/26 13:37	02/26/26 17:11	RCC	EPA 200.8	

MDH Sample Number: 26B1348-02

Location ID: 113
Sampling Point: 460987

Collect Date: 02/16/26
Collect Time: 12:30
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6B0951	02/26/26 13:37	02/26/26 17:12	RCC	EPA 200.8	

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-03

Location ID: 115
Sampling Point: 460988

Collect Date: 02/16/26
Collect Time: 12:30
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6B0951	02/26/26 13:37	02/26/26 17:13	RCC	EPA 200.8	

MDH Sample Number: 26B1348-04

Location ID: 116
Sampling Point: 460989

Collect Date: 02/16/26
Collect Time: 13:04
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6B0951	02/26/26 13:37	02/26/26 17:13	RCC	EPA 200.8	

MDH Sample Number: 26B1348-05

Location ID: 117
Sampling Point: 460990

Collect Date: 02/16/26
Collect Time: 13:06
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6B0951	02/26/26 13:37	02/26/26 17:14	RCC	EPA 200.8	

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-06

Location ID: 118
Sampling Point: 460991

Collect Date: 02/16/26
Collect Time: 13:08
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6B0951	02/26/26 13:37	02/26/26 17:15	RCC	EPA 200.8	

MDH Sample Number: 26B1348-07

Location ID: 119
Sampling Point: 460992

Collect Date: 02/16/26
Collect Time: 13:10
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6B0951	02/26/26 13:37	02/26/26 17:16	RCC	EPA 200.8	

MDH Sample Number: 26B1348-08

Location ID: 120
Sampling Point: 460993

Collect Date: 02/16/26
Collect Time: 13:15
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6B0951	02/26/26 13:37	02/26/26 17:18	RCC	EPA 200.8	

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-09

Location ID: 121
Sampling Point: 460994

Collect Date: 02/16/26
Collect Time: 13:15
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6B0951	02/26/26 13:37	02/26/26 17:19	RCC	EPA 200.8	

MDH Sample Number: 26B1348-10

Location ID: 122
Sampling Point: 460995

Collect Date: 02/16/26
Collect Time: 13:20
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:24	RCC	EPA 200.8	

MDH Sample Number: 26B1348-11

Location ID: 126
Sampling Point: 460996

Collect Date: 02/16/26
Collect Time: 13:15
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:25	RCC	EPA 200.8	

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-12

Location ID: 127A-1
Sampling Point: 460983

Collect Date: 02/16/26
Collect Time: 13:20
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:26	RCC	EPA 200.8	

MDH Sample Number: 26B1348-13

Location ID: 127A-2
Sampling Point: 460984

Collect Date: 02/16/26
Collect Time: 13:20
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:29	RCC	EPA 200.8	

MDH Sample Number: 26B1348-14

Location ID: 127A-3
Sampling Point: 460985

Collect Date: 02/16/26
Collect Time: 13:20
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:30	RCC	EPA 200.8	

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-15

Location ID: 129
Sampling Point: 460997

Collect Date: 02/16/26
Collect Time: 13:15
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:30	RCC	EPA 200.8	

MDH Sample Number: 26B1348-16

Location ID: 131
Sampling Point: 460998

Collect Date: 02/16/26
Collect Time: 13:10
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:31	RCC	EPA 200.8	

MDH Sample Number: 26B1348-17

Location ID: 132
Sampling Point: 460982

Collect Date: 02/16/26
Collect Time: 13:09
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:32	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-18

Location ID: 139-1
Sampling Point: 460999

Collect Date: 02/16/26
Collect Time: 13:04
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:33	RCC	EPA 200.8	

MDH Sample Number: 26B1348-19

Location ID: 139-2
Sampling Point: 461001

Collect Date: 02/16/26
Collect Time: 13:04
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:34	RCC	EPA 200.8	

MDH Sample Number: 26B1348-20

Location ID: 140
Sampling Point: 461000

Collect Date: 02/16/26
Collect Time: 12:30
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:36	RCC	EPA 200.8	

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-21

Location ID: 152
Sampling Point: 460959

Collect Date: 02/16/26
Collect Time: 14:10
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:37	RCC	EPA 200.8	

MDH Sample Number: 26B1348-22

Location ID: 153A
Sampling Point: 460833

Collect Date: 02/16/26
Collect Time: 14:10
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:38	RCC	EPA 200.8	

MDH Sample Number: 26B1348-23

Location ID: 153B
Sampling Point: 460957

Collect Date: 02/16/26
Collect Time: 14:10
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:39	RCC	EPA 200.8	

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-24

Location ID: 153C
Sampling Point: 460958

Collect Date: 02/16/26
Collect Time: 14:10
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:40	RCC	EPA 200.8	

MDH Sample Number: 26B1348-25

Location ID: 154
Sampling Point: 460832

Collect Date: 02/16/26
Collect Time: 14:30
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:41	RCC	EPA 200.8	

MDH Sample Number: 26B1348-26

Location ID: 166A-1
Sampling Point: 460960

Collect Date: 02/16/26
Collect Time: 12:15
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:41	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-27

Location ID: 166A-2
Sampling Point: 460961

Collect Date: 02/16/26
Collect Time: 12:15
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:42	RCC	EPA 200.8	

MDH Sample Number: 26B1348-28

Location ID: 166A-3
Sampling Point: 460962

Collect Date: 02/16/26
Collect Time: 12:15
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0661	03/02/26 07:38	03/02/26 10:45	RCC	EPA 200.8	

MDH Sample Number: 26B1348-29

Location ID: 168-1
Sampling Point: 461012

Collect Date: 02/16/26
Collect Time: 13:30
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 10:50	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-30

Location ID: 168-2
Sampling Point: 461013

Collect Date: 02/16/26
Collect Time: 13:30
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 10:51	RCC	EPA 200.8	

MDH Sample Number: 26B1348-31

Location ID: 182-1
Sampling Point: 461006

Collect Date: 02/16/26
Collect Time: 13:33
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 10:52	RCC	EPA 200.8	

MDH Sample Number: 26B1348-32

Location ID: 182-2
Sampling Point: 461007

Collect Date: 02/16/26
Collect Time: 13:33
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 10:54	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-33

Location ID: 182-3
Sampling Point: 461008

Collect Date: 02/16/26
Collect Time: 13:33
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 10:55	RCC	EPA 200.8	

MDH Sample Number: 26B1348-34

Location ID: 182-4
Sampling Point: 461009

Collect Date: 02/16/26
Collect Time: 13:33
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 10:56	RCC	EPA 200.8	

MDH Sample Number: 26B1348-35

Location ID: 182-5
Sampling Point: 461010

Collect Date: 02/16/26
Collect Time: 13:45
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 10:57	RCC	EPA 200.8	

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-36

Location ID: 182-6
Sampling Point: 461011

Collect Date: 02/16/26
Collect Time: 14:50
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 10:58	RCC	EPA 200.8	

MDH Sample Number: 26B1348-37

Location ID: 189-1
Sampling Point: 461003

Collect Date: 02/16/26
Collect Time: 13:45
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 10:58	RCC	EPA 200.8	

MDH Sample Number: 26B1348-38

Location ID: 189-2
Sampling Point: 461004

Collect Date: 02/16/26
Collect Time: 13:33
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 10:59	RCC	EPA 200.8	

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-39

Location ID: 189-3
Sampling Point: 461005

Collect Date: 02/16/26
Collect Time: 13:45
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 11:02	RCC	EPA 200.8	

MDH Sample Number: 26B1348-40

Location ID: 218A-1
Sampling Point: 461014

Collect Date: 02/16/26
Collect Time: 14:45
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 11:03	RCC	EPA 200.8	

MDH Sample Number: 26B1348-41

Location ID: 218A-2
Sampling Point: 461015

Collect Date: 02/16/26
Collect Time: 14:45
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 11:04	RCC	EPA 200.8	

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-42

Location ID: 218A-3
Sampling Point: 461016

Collect Date: 02/16/26
Collect Time: 14:45
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 11:04	RCC	EPA 200.8	

MDH Sample Number: 26B1348-43

Location ID: 230
Sampling Point: 461017

Collect Date: 02/16/26
Collect Time: 14:45
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 11:05	RCC	EPA 200.8	

MDH Sample Number: 26B1348-44

Location ID: 239-1
Sampling Point: 461021

Collect Date: 02/16/26
Collect Time: 14:42
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 11:06	RCC	EPA 200.8	

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-45

Location ID: 239-2
Sampling Point: 461022

Collect Date: 02/16/26
Collect Time: 14:42
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 11:07	RCC	EPA 200.8	

MDH Sample Number: 26B1348-46

Location ID: 253A-1
Sampling Point: 461018

Collect Date: 02/16/26
Collect Time: 14:42
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 11:08	RCC	EPA 200.8	

MDH Sample Number: 26B1348-47

Location ID: 253A-2
Sampling Point: 461019

Collect Date: 02/16/26
Collect Time: 14:42
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 11:10	RCC	EPA 200.8	

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-48

Location ID: 253A-3
Sampling Point: 461020

Collect Date: 02/16/26
Collect Time: 14:42
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0662	03/02/26 07:40	03/02/26 11:11	RCC	EPA 200.8	

MDH Sample Number: 26B1348-49

Location ID: 300-1
Sampling Point: 461023

Collect Date: 02/16/26
Collect Time: 15:34
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0782	03/09/26 09:03	03/09/26 13:23	RCC	EPA 200.8	

MDH Sample Number: 26B1348-50

Location ID: 300-2
Sampling Point: 461024

Collect Date: 02/16/26
Collect Time: 15:34
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0782	03/09/26 09:03	03/09/26 13:24	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

MDH Sample Number: 26B1348-51

Location ID: 300-3
Sampling Point: 461025

Collect Date: 02/16/26
Collect Time: 15:34
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B6C0782	03/09/26 09:03	03/09/26 13:25	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

Results were produced by Minnesota Department of Health, except where noted.

Batch B6B0951 - EPA 200 Series Prep

Blank (B6B0951-BLK1)

Prepared: 02/26/26 13:37 Analyzed: 02/26/26 16:56

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L							RCC	

LCS (B6B0951-BS1)

Prepared: 02/26/26 13:37 Analyzed: 02/26/26 16:57

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	46.3		ug/L	50		93	85-115			RCC	

Duplicate (B6B0951-DUP1)

Source: 26B1165-08

Prepared: 02/26/26 13:37 Analyzed: 02/26/26 17:01

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L		<				20	RCC	

Duplicate (B6B0951-DUP2)

Source: 26B1348-07

Prepared: 02/26/26 13:37 Analyzed: 02/26/26 17:17

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	0.45	1.00	ug/L		<			0.5	20	RCC	

Matrix Spike (B6B0951-MS1)

Source: 26B1165-08

Prepared: 02/26/26 13:37 Analyzed: 02/26/26 17:01

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	42.4		ug/L	50		85	70-130			RCC	

Matrix Spike (B6B0951-MS2)

Source: 26B1348-07

Prepared: 02/26/26 13:37 Analyzed: 02/26/26 17:18

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	42.4		ug/L	50		84	70-130			RCC	

Batch B6C0661 - EPA 200 Series Prep

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

Results were produced by Minnesota Department of Health, except where noted.

Batch B6C0661 - EPA 200 Series Prep

Blank (B6C0661-BLK1)

Prepared: 03/02/26 07:38 Analyzed: 03/02/26 10:23

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L							RCC	

LCS (B6C0661-BS1)

Prepared: 03/02/26 07:38 Analyzed: 03/02/26 10:24

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	51.3		ug/L	50		103	85-115			RCC	

Duplicate (B6C0661-DUP1)

Source: 26B1348-12

Prepared: 03/02/26 07:38 Analyzed: 03/02/26 10:27

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L		<				20	RCC	

Duplicate (B6C0661-DUP2)

Source: 26B1348-27

Prepared: 03/02/26 07:38 Analyzed: 03/02/26 10:43

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	0.13	1.00	ug/L		<			0.2	20	RCC	

Matrix Spike (B6C0661-MS1)

Source: 26B1348-12

Prepared: 03/02/26 07:38 Analyzed: 03/02/26 10:28

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	46.0		ug/L	50		92	70-130			RCC	

Matrix Spike (B6C0661-MS2)

Source: 26B1348-27

Prepared: 03/02/26 07:38 Analyzed: 03/02/26 10:44

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	47.4		ug/L	50		95	70-130			RCC	

Batch B6C0662 - EPA 200 Series Prep

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

Results were produced by Minnesota Department of Health, except where noted.

Batch B6C0662 - EPA 200 Series Prep

Blank (B6C0662-BLK1)

Prepared: 03/02/26 07:40 Analyzed: 03/02/26 10:48

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L							RCC	

LCS (B6C0662-BS1)

Prepared: 03/02/26 07:40 Analyzed: 03/02/26 10:49

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	49.6		ug/L	50		99	85-115			RCC	

Duplicate (B6C0662-DUP1)

Source: 26B1348-31

Prepared: 03/02/26 07:40 Analyzed: 03/02/26 10:52

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L		<				20	RCC	

Duplicate (B6C0662-DUP2)

Source: 26B1348-46

Prepared: 03/02/26 07:40 Analyzed: 03/02/26 11:09

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L		<				20	RCC	

Matrix Spike (B6C0662-MS1)

Source: 26B1348-31

Prepared: 03/02/26 07:40 Analyzed: 03/02/26 10:53

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	47.0		ug/L	50		94	70-130			RCC	

Matrix Spike (B6C0662-MS2)

Source: 26B1348-46

Prepared: 03/02/26 07:40 Analyzed: 03/02/26 11:09

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	46.4		ug/L	50		93	70-130			RCC	

Batch B6C0782 - EPA 200 Series Prep

FINAL REPORT

Report ID: 03132026161310

Generated: 3/13/2026 4:13:07PM

Authorized by:

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: St. Croix Preparatory

Results were produced by Minnesota Department of Health, except where noted.

Batch B6C0782 - EPA 200 Series Prep

Blank (B6C0782-BLK1)

Prepared: 03/09/26 09:03 Analyzed: 03/09/26 13:21

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L							RCC	

LCS (B6C0782-BS1)

Prepared: 03/09/26 09:03 Analyzed: 03/09/26 13:22

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	47.8		ug/L	50		96	85-115			RCC	

Duplicate (B6C0782-DUP1)

Source: 26B1348-51

Prepared: 03/09/26 09:03 Analyzed: 03/09/26 13:26

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L		<				20	RCC	

Matrix Spike (B6C0782-MS1)

Source: 26B1348-51

Prepared: 03/09/26 09:03 Analyzed: 03/09/26 13:26

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	49.6		ug/L	50		99	70-130			RCC	

Work Order Comments

Samples were received in proper condition.

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health